# SeaHawk LD310 Quick Start Guide



Thank you for purchasing a SeaHawk LD310 single-zone leak detection controller. This guide outlines device installation and operation.

If you need further assistance, please visit the support section of our website - http://www.rletech.com/support/ or call us at 800.518.1519.



v1.2 (09/2013)



© Raymond & Lae Engineering, Inc. 2011. All rights reserved. RLE® is a registered trademark and Seahawk<sup>TM</sup>, Falcon<sup>TM</sup>, and Raptor<sup>TM</sup> are trademarks of Raymond & Lae Engineering, Inc. The products sold by Raymond & Lae Engineering, Inc. are subject to the limited warranty, limited liability, and other terms and conditions of sale set forth at http://rletech.com/RLE-Terms-and-Conditions.html.

#### **Supplies for Installation** \_\_\_

#### Included with the LD310

15 foot (4.57m) leader cable End-of-line terminator (EOL) Wall mounting hardware

#### Available from RLE, sold separately

SeaHawk sensing cable, up to 300 feet (91.4m) 100-240V to 5VDC power supply (WA-DC-5-ST)

#### **Mount the Device**.

Remove the cover from the LD310 to expose the mounting holes. Use the provided hardware to mount the LD310 in the desired location.

## **Connect the Sensing Cable\_**

Leader cable is used to connect sensing cable to the LD310, since sensing cable cannot connect directly to the device.

1. Insert the four stripped wires of the leader cable into the appropriate slots in the Cable Input terminal block at the bottom right corner of the LD310:

White wire: insert into pinout labeled **W**Black wire: insert into pinout labeled **B**Green wire: insert into pinout labeled **G**Red wire: insert into pinout labeled **R** 

2. Unscrew the EOL from the end of the leader cable.

- 3. Attach the length of sensing cable to the leader cable.
- 4. Route the sensing cable according to your cable layout diagram.
- 5. Secure the EOL to the unoccupied end of the sensing cable.

#### Connect the Relay Outputs\_

The LD310 can be used as a stand-alone device, but it does have two Form C relay outputs that communicate leak and fault status to another device or system. If you wish to use the relay outputs, wire them at this time.

#### **Connect the Power and Modbus Relay Output**

The LD310 requires a 5 VDC power supply. To avoid product damage or personal injury, wire power to the slots labelled + and – in the DC IN terminal blocks. Establish all wiring connections, including sensing cable, relay outputs, and power before you activate the board's power supply.

### **Program Jumpers**\_

The LD310 has three sets of three-pin jumpers. JP1 is used to configure the sensitivity of the leak setting. JP2 configures the relay outputs. JP3 configures the audible alarm. If you change the jumpers, you must cycle power to the LD310 in order for it to recognize the change.

JP1	
Set the Leak Sensitivity	
Jumper spans top 2 pins	High sensitivity - most sensitive - system alarms with .5" (13mm) wetted cable
Jumper is not installed	Medium sensitivity - system alarms with 2" (51mm) wetted cable
Jumper spans bottom 2 pins	Low sensitivity - least sensitive - system alarms with 6" (152mm) wetted cable
JP2	
Configure the Relay Outputs	
Jumper spans top 2 pins	Relays are supervised - the relays remains ON until either power is disabled or an alarm is detected - at which time the relays turn OFF.
Jumper spans bottom 2 pins	Relays are non-supervised - the relays remains OFF until an alarm is detected - at which time the relays turns ON.
JP3	
Configure the Audible Alarm	
Jumper is not installed	Audible alarm is disabled.
Jumper spans bottom 2 pins	Audible alarm is enabled.

#### **LED**

The L<del>D310 has one LED, which is used to report a variety of conditions.</del>

**Power On / Normal** - The LED is on and displays a solid green color during normal operation with no alarm present.

Cable Break - The LED flashes orange while the audible alarm sounds. Once

the alarm silence button is pushed, the LED will continue to flash orange slowly until the cable break is resolved.

**Leak** - The LED flashes red while the audible alarm sounds. Once the alarm silence button is pushed, the LED will continue to display a solid red color until the leak is resolved and the cable is dry.

#### **Audible Alarm and Silence/Test/Reset Button**

The LD310 has one push-button switch, which is used to silence the audible alarm and to test and reset the system.

The audible alarm sounds when a cable break or leak is detected. When the audible alarm is activated, push the button once to silence the alarm.

Test mode allows the LD310 to test its internal components. To initiate test mode, push and hold the button for approximately 5 seconds - when the LED flashes red and green, the audible alarm sounds, and the relays activate (change state) the test is complete. Release the button.

When you release the button after the test cycle, the entire unit resets and the LED returns to green. If there was a leak or cable break present before you ran the test and that leak or break is still present, the unit will alarm for this condition again after a few seconds.

#### **Test the System**

Once the LD310 is set up, you should test the system. If the LD310 is connected to a BMS or NMS, notify monitoring personnel before you test.

To verify the LD310's functionality, test three points within the length of sensing cable - one at the beginning, one in the middle of the length, and another near the end of the length of cable.

There are a variety of ways to simulate a leak.

- Pour a small puddle of water on the cable while it rests on the floor.
- Dunk the cable in a cup of water.
- Wet a paper towel or rag and wrap it loosely around the cable. This is popular if the cable is used in pipe applications. Be careful to wrap the wet cloth loosely around the cable. Do not put pressure on the cable.

Remove simulated leak sources. Return the system to its normal operating state.

To test the cable fault alarm, remove the end-of-line terminator (EOL) from the end of the sensing cable. This will cause a cable break, which should be reported appropriately by the LD310. Once the cable break alarm is verified, reapply the EOL and ensure the system returns to its normal operating state.

