

HS-100 Low Voltage Card Key Switch



Installation Instructions

SPECIFICATIONS

- Voltage 24VDC/24VAC (Class 2)
- Current Consumption
 - DC Max. 25mA
 - AC Max. 10mA
- Outputs:
 - Isolated relay (N.O./N.C.) 1A/30VDC/VAC SPDT
- Egress Time Delay 30 seconds
- Environment Indoor use only
 - Operating Temperature 32° to 131°F (0° to 55°C)
 - Humidity 95% RH, non-condensing
- Card Slot accepts standard size hotel card keys with dimensions 2.125"W x 3.375"H x 0.034"D
(53.975mm x 85.725mm x 0.8636mm)
- Tools Needed
Insulated Screwdriver, Wire Strippers



Santa Clara, CA 95050

DESCRIPTION

The HS-100 is a low voltage card key switch that enables or disables power to electric circuits and loads in a hotel guest room or similar site. When a hotel door entry card key (or the key fob HS-FOB) is inserted in the HS-100 card slot the controlled circuits are energized. When the hotel door entry card key (or HS-FOB) is removed, the controlled circuits will remain energized for 30 seconds more to allow safe egress from the hotel room. After this time delay elapses, they will be de-energized. To restore power to the room (that is, to the controlled circuits and loads), the occupant will need to reinsert the hotel door entry card key into the HS-100 card slot.

Lighted Card Slot

To help you locate the HS-100 in a dark room, two green LEDs illuminate the card slot where the hotel door entry card key or the key fob HS-FOB should be inserted. When the card or HS-FOB is in the slot, the green LEDs are off.

INSTALLATION AND WIRING

WARNING

Disconnect power to the wall switch box by turning OFF the circuit breaker or removing the fuse for the circuit before installing the HS-100, replacing lamps, or doing any electrical work.

Install in compliance with all applicable codes and standards.

1. Make sure the insulation is stripped off the wires to expose their copper cores to the length indicated by the "Strip Gauge" shown in Figure 1 (approx. 3/8").
2. Insert wires into the terminals on the HS-100 as indicated in these instructions for either power pack wiring (Figure 2) or building control system wiring (Figure 3). Make sure they are securely clamped.




Figure 1: Strip Gauge

Power Pack Wiring:

- a) Install the power pack according to its instructions.
- b) Connect the power pack wires:
 - BLUE wire to isolated relay common (RLY COMM) terminal on the HS-100.
 - RED wire (+24VDC) to the normally open relay (N.O.) terminal and to the +24V IN terminal on the HS-100.
 - BLACK wire (Return) to the common (COMM) terminal on the HS-100.




Figure 2: Wiring to power pack

When controlling multiple circuits in a room, call Technical Support at 800.879.8585 for diagrams.

Building Control System Wiring:

The HS-100's Isolated Relay allows integration with a lighting control panel, a building automation system (BAS), an energy management system (EMS) or any other building control system that accepts a dry contact closure as an input signal. Connect the wires coming from the building control system as follows:

- +24VDC or +24VAC Class 2 supply to the +24V IN terminal on the HS-100.
- Supply common to COMM terminal on the HS-100.
- Wire the Isolated Relay according to the building control system requirements. The isolated relay is rated for 1A @ 30VAC/VDC:

Normally Closed (N.C.) - Open when card key is in card slot.

Normally Open (N.O.) - Closed when card key is in card slot.

Isolated Relay Common (RLY COMM) must be used for proper operation.




Figure 3: Class 2 wiring to building control system

3. Mount the HS-100 in the wall box with the mounting screws provided.
4. Attach the cover plate then turn the power on.

TROUBLESHOOTING

Lighted card slot is OFF; no response from controlled loads in the guest room when card is inserted in slot.

- Make sure the circuit breaker that feeds the controlled guest room loads is on and functioning.
- If the guest room loads are still not energized, turn power off and verify that the HS-100 is wired correctly and that all wires are tightly secured inside the wiring terminals.
- If loads still do not respond properly after following troubleshooting, turn OFF power to the circuit and call technical support at 1.800.879.8585.

Lighted card slot is ON; no response from controlled loads in the guest room when card is inserted in slot or removed from it.

- If using a power pack, a direct connection between the Red (+24VDC) and the Blue thin wires on the power pack should close the power pack's relay and the controlled loads in the guest room should be energized. Turn power off, make this test connection and turn power back on. The controlled loads should be energized. If they are, turn power off and correctly rewire the HS-100 making sure that all wires are tightly secured inside the wiring terminals.
- If the controlled loads do not energize using the test connection, call technical support.

ORDERING INFORMATION

Catalog #	Description
HS-100	Low Voltage Card Key Switch; 24VDC/VAC
HS-150	Line Voltage Card Key Switch; 120-277VAC, 50/60Hz
HS-FOB*	Key Fob accessory for use when room access uses a standard key entry or other system without standard size hotel card key
HS-WP**	Cover plate for single-gang box
HS-WPR	Cover plate for triple-gang box with decorator switch option (card slot on the right)
HS-WPL	Cover plate for triple-gang box with decorator switch option (card slot on the left)

Hotel Card Key Switches, Key Fobs and Cover Plates are available in White (-W), Light Almond (-LA), Ivory (-I), Black (-B), and Grey (-G)

* Not needed when hotel uses card key entry system.

** One HS-WP included with each switch.

WARRANTY INFORMATION

Watt Stopper/Legrand warrants its products to be free of defects in materials and workmanship for a period of five (5) years. There are no obligations or liabilities on the part of Watt Stopper/Legrand for consequential damages arising out of, or in connection with, the use or performance of this product or other indirect damages with respect to loss of property, revenue or profit, or cost of removal, installation or reinstallation.



2800 De La Cruz Boulevard, Santa Clara, CA 95050
Technical Support: 800.879.8585
www.wattstopper.com
08210r2 08/2007

Please
Recycle

