

ORDERING INFORMATION								
VALVE SPECIFICATION				NON-SPRING		SPRING RETURN		
Port	Valve #	Cv (Kv)	Size	Floating	Proportional	Two-pos	Proportional	Floating
Two-way	VBB(S)N00	0.3 (0.3)	1/2"	M131A00	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N01	0.7 (0.6)	1/2"	M131A01	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N02	1.2 (1.0)	1/2"	M132A00	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N03	2.1 (1.8)	1/2"	M132A01	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N04	3.5 (3.0)	1/2"	LVB24-3	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N05	4.7 (4.1)	1/2"	LVB24-3	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N06	7.7 (6.7)	1/2"	LVB24-3	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N07	10 (8.7)	1/2"	LVB24-3	LVB24-SR	LF24	LF24-SR	LVKB24-3
Two-way	VBB(S)N10		3/4"					
Two-way	VBB(S)N11		3/4"					
Two-way	VBB(S)N12		3/4"					
Two-way	VBB(S)N13		3/4"					
Two-way	VBB(S)N14		3/4"					
Two-way	VBB(S)N15		3/4"					
Two-way	VBB(S)N16							
Two-way	VBB(S)N17							
Three-way	G315B-G	2.2	1/2"	SVB24-3	SVB24-SR	NFBUP-X1	NFBUP-SR-X1	SVKB24-3
Three-way	G315B-J	4.4	1/2"	SVB24-3	SVB24-SR	NFBUP-X1	NFBUP-SR-X1	SVKB24-3
Three-way	G320B-K	6.8	3/4"	SVB24-3	SVB24-SR	NFBUP-X1	NFBUP-SR-X1	SVKB24-3
Three-way	G325B-L	14.0	1"	SVB24-3	SVB24-SR	NFBUP-X1	NFBUP-SR-X1	SVKB24-3
Three-way	G332B-M	20.0	1-1/4"	SVB24-3	SVB24-SR	NFBUP-X1	NFBUP-SR-X1	SVKB24-3
Three-way	G340B-N	28.0	1-1/2"	SVB24-3	SVB24-SR	AFBUP-X1	AFB24-SR-X1	SVKB24-3
Three-way	G350B-N	40.0	2"	SVB24-3	SVB24-SR	AFBUP-X1	AFB24-SR-X1	SVKB24-3

MODEL	DESCRIPTION
G_ _ _ _ _ +	Globe valve with specifications listed ab
-----	Compatible actuator as listed above (other options available from factory)

Note:	-MFT (non-spring or electronic fail-safe)	Multi-Function technology model actuators are also available. Replace the -SR with -MFT or -MFT-X1 to the base model number of the actuator and specify the control signal
	-MFT-X1 (for spring return)	

Note:	(S) next to Valve Part number indicates stainless steel valve stem and seat. (Replace B with S)
--------------	---

Note:	On Spring Return Actuators only, add -S to the end of the base actuator model number for auxilliary switch
--------------	--