


2306 Airport Road


Waterford • Michigan • 48327-1209 Phone: 248-673-9898 • Fax: 248-673-1246

E-mail: info@sti-usa.com • Web: www.sti-usa.com

Taylor House • 34 Sherwood Road • Bromsgrove Worcestershire • B60 3DR • England Tel: +44 (0)1527 520 999 • Fax: +44 (0)1527 501 999

Tel: +44 (0)1527 520 999 • Fax: +44 (0)1527 501 999 E-mail: info@sti-emea.com • Web: www.sti-emea.com





PRODUCT DIMENSIONS

INSTALLATION NOTES

Before drilling mounting holes place spacer, frame and cover over your device. Position it so device functions properly and cover closes with no interference.

- 1. Remove windows from spacer.
- 2. Place cover and frame onto spacer. Center over device and transfer hole locations onto wall using an 11/64 drill bit.
- 3. Remove cover, frame, spacer and drill mounting holes in wall. If using anchors provided, drill holes with 7/32 drill bit. If using only screws provided, drill holes with 7/64 drill bit. Drill all mounting holes 1 in. deep.
- 4. Cut gasket at center of window opening. Place gasket behind conduit and position cut end of gasket to bottom of device to prevent moisture from entering.
- Place window, conduit window or conduit gasket into spacer window opening (top and bottom).
- 6. With cover opened, place full assembly over device and mount with screws provided.

⚠ WARNING: This product can expose you to chemicals including Dichloromethane, which is known to the State of California to cause cancer, and Bisphenol A (BPA), which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

Three year warranty or a one year limited warranty (from date of purchase) on most products. See website for details. Electronic warranty form at **www.sti-usa.com/wc14**.

INSTALLATION OF STI-1331 UNIVERSAL STOPPER® SPACER

All specifications and information shown were current as of publication and are subject to change without notice.

1331IS APRIL2016