634RF 4 AmpPower Supply

The SDC 634RF Power Supplies have been developed specifically to support electric locks and access controls. The high performance, heavy-duty 4 Amp circuitry is ideal for inductive loads and multi-door applications. The modular design is built around several different application control modules to meet your specific needs for virtually any electric lock system. Documentation is provided to ensure a well organized installation for individual or multi-door systems that may include locking devices, access controls, station controls and consoles for remote control, annunciation and auxiliary emergency release interface. SDC 600 Series power supplies are manufactured according to Quality Assurance standards.





FEATURES

Filtered and Regulated

The output filtering stabilizes the DC output voltage and eliminates AC line noise. The solid state regulator maintains the selected output voltage at 12VDC or 24VDC regardless of the output load changes, including battery charging.

- Field Selectable 12 or 24VDC
 The output is field selectable for 12 or 24VDC output.
- Class 2 Output

The 634RF Power Supply may be configured to use one 4 Amp output or two 2 Amp, Class 2 outputs. Where permitted by code, conduit is not required for low voltage wiring when using Class 2 outputs. The total current draw from all outputs must not exceed 4 Amps.

- LED System Status Indicator
 Amber AC and DC voltages are OK
 Green No DC output
 Red No AC input, powered by batteries
- Large Heavy Gauge Enclosure
 Model 634RF is housed in a 16 gauge, 16"W x 14"H x 6.5"D cabinet large enough to accommodate several additional modules and six 8 Amp hour batteries with plenty of room for wiring.
- Battery Charger Output
 A separate PTC protected, battery charger output provides 13.5VDC or 27VDC.

 Emergency Release Input (Standard)
 A signal input from the fire life safety system turns off the secondary output releasing all failsafe locks.
 When not used for emergency release, this input

may be used as main on-off control.

- California Compliant Manual Reset of Emergency Release and AC Power Loss (Optional)
 When this feature is required, should an AC power loss occur or the emergency release input is actuated, personnel must restore secondary output power manually at the power supply after the emergency release signal is reset and/or AC power is restored.
- Low Battery Disconnect (Standard)
 Batteries are disconnected from the output circuit prior to deep discharge preventing battery destruction.
- Isolated Charging Circuit (Standard)
 While the charging output is 13.5VDC or 27VDC,
 the secondary output is unaffected and precisely
 maintained at the selected 12 or 24VDC. This
 ensures system components are powered by their
 specified voltage. The secondary output current is
 maintained at the full 4 Amp capacity and is not de rated when charging batteries.

















SPECIFICATIONS

Input	1 Amp @115VAC 50/60 Hz (230VAC 50/60Hz Optional, Not UL listed)	
Input Protection	1 Amp, Manually Resettable Circuit Breaker	
Secondary Output	Selectable One, 4 Amp @ 12VDC or 24VDC or Two, Class 2, 2 Amp @12VDC or 24VDC	
Battery Protection	Auto Resetting Poly Fuse per Output	

Battery Charger Output	500 mA @ 13.5 or 27VDC
Battery Charger Protection	Auto Resetting Poly Fuse
Dimensions	16" W x 14" H x 6.5" D
Material	16 Gauge Steel

PRODUCT SKU SAMPLE: 634RF 14-2 UR4-8

HOW TO ORDER

1| SPECIFY MODEL

634RF 4 Amp Power Supply

One 4 Amp Output or Two 2 Amp Class 2 Outputs Standard

2 | SPECIFY OPTIONS

Cover Mounted Manual Reset Switch **MR**

for Fire/Emergency Release

System On-Off Push Switch inside Pow-PS-1

er Supply Enclosure

PS-1A System On-Off Push Switch on Enclo-

sure Cover

7 Day - Skip a Day Programmable Timer 14-2

PC 6 ft. Power Cord KL Key Lock Cover 220V/230V 230VAC, 50/60Hz

3| SPECIFY CONTROL MODULES

12VDC Regulated and Filtered Output Module **12VR**

FB-4 Four 2 Amp fuse protected outputs

PSM Power Supply Remote Monitoring Module

UR1 Universal Door Controllers

UR2-4 Two Station Door Controllers

UR4-8 Four Station Door Controllers

Control Relay - 4 Independent DPDT Relays CR4

ACM-1 Access Control Module

PB-8 8 Amp Power Booster

PB-16 16 Amp Power Booster

see page <?> for more info on control modules



634RF x 2-UR4-8 x 2 RB12V7

TABLE 1: CONTROL MODULE CAPACITY *

Power Supply:	634RF	
Battery Qty.	0-2	3-6
	RB1	2 V 7
FB4	8	4
12VR	4	4
PSM	1	1
UR-1	4	4
UR2-4, UR4-8	2	1
CR-4	4	2
ACM-1	4	2
PB-8, PB-16	4	4

^{*} Total combined load of modules and access control hardware may not exceed 4 amp.

TABLE 2: 12VDC STANDBY POWER

8 Ah Battery Qty	1	2	4	6
Amp Hours	8Ah	16Ah	32Ah	48Ah
Load/Amps	Power Back-up Time in Hours			
2	3	6.5	15	19
2.5	2.3	5	11.5	15
3	1.8	4	9	12.5
3.5	1.5	3.4	7.5	11
4	1.3	2.8	6.5	6.1

TABLE 3: 24VDC STANDBY POWER

8 Ah Battery Qty	2	4	6	
Amp Hours	8Ah	16Ah	24Ah	
Load/Amps	Power Back-up Time in Hours			
2	3	6.5	11	
2.5	2.3	5	8.3	
3	1.8	4	6.5	
3.5	1.5	3.4	5.5	
4	1.3	2.8	4.8	

SDC power supplies equipped with batteries provide continuous operation of access controls, locking devices and peripheral components during a power failure. See Table 2 & 3 to determine battery requirements for standby power.





12VDC, 8 Amp Hour Battery



